सत्यमेव जयते

Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
Ghoshpara Road, P.O.:- Bengal Enamel, Pin :- 743122

Memo No.: FSR/0125186211100079 **Date : 08-08-2024**

From :
Divisional Fire Officer
North 24 Parganas Division
West Bengal Fire & Emergency Services

To :
Gopal Gurukul International School
MOUZA- BHATENDA, KHATIAN NO- 279/2, JL NO- 28, DAG NO- 20,24,25,26/734,26,PO - RAJARHAT, PS- RAJARHAT, PIN- 700135, NORTH 24 PARGANAS

Sub : Revised Fire safety Recommendations for the existing construction of G+III storied building under group of Educational in the name & style of Gopal Gurukul International School (Previously named as per earlier issued FSR- NETAI CHANDRA GHOSH MEMORIAL TRUST), premises at Mouza - Bhatenda, khatian no- 279/2, JL no - 28, Dag no- 20, 24, 25, 26/734,26, Post office - Rajarhat, Police Station – Rajarhat, Kol-700135.

.

This is in reference to your AIN 211882406300000647 dated 07-Aug-2024 regarding the Revised Fire safety Recommendations for the existing construction of G+III storied building under group of Educational in the name & style of Gopal Gurukul International School (Previously named as per earlier issued FSR- NETAI CHANDRA GHOSH MEMORIAL TRUST), premises at Mouza - Bhatenda, khatian no- 279/2, JL no - 28, Dag no- 20, 24, 25, 26/734,26, Post office - Rajarhat, Police Station – Rajarhat, Kol-700135.

.

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this office is issuing Revised Fire Safety Recommendation in favor of the aforesaid building subject to the compliance of the

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211882406300000647

Recommendation :

1. Maintain & comply all the stipulated Recommendations, prescribed in the earlier issued FSR from this Office, vide Memo No: FSR/0125186211100079, Dated: 24-05-2021 strictly.

2. Fire License shall have to be obtained from the License section of the Department for proposed storing of highly combustible articles and processing with L.P.G, which come under the purview of License Section.

3. Fire Notice for fire fighting and evacuation from the building shall be prepared and be displayed at a vulnerable places of the building.

4. Directional sign of escape routes shall be displayed prominently.

5. The employees and security staff shall be conversant with installed fire fighting equipments of the building and to operate in the event of Fire & Testing.

6. Arrangement shall be made regular checking, testing and proper maintenance of all the fire safety installation and equipments installed in the building to keep them in perfectly good working conditions at all times.

7. Mock fire practice and evacuation drill shall be performed periodically with participation of all occupants of the building.

This shall be treated as Revised Fire Safety Recommendations on compliance of all the above fire and life safety recommendations, the Divisional Fire Officer, North 24 Parganas Division, West Bengal Fire & Emergency Services shall be approached for necessary inspection and testing of the installation, Fire Safety Certificate in favour of the occupancy shall be issued on being satisfied with the tests and performances of safety aspects of installation of the building.

N.B. : Any deviation and changes the nature of use of the building in respect of the approved plan drawing, without obtaining prior permission from this office, this fire safety recommendation will be treated as cancelled.

Memo No.: FSR/0125186211100079

Signature Not Verified
Digitally Signed.
Name: SAROJ KUMAR BAG
Date: 08-Aug-2024 15:40:14
Reason: D-Sign
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire and Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211882406300000647